



LABORATORY TEST REPORT

Of

'Turflex Premium' Artificial Turf



In accordance with

EN 13501-1: Flammability

For

PaviFLEX GYM FLOORING

**Ctra. Murcia-Alicante Km. 49,100
03330 Crevillente
Alicante**

| REPORT STATUS: | FINAL | Signature | Date |
|----------------|-----------------------|--|------------|
| Report No: | 14386/5446 | | |
| Prepared By | N MacPhee |  | 23/11/2012 |
| | Laboratory Supervisor | | |
| Checked By | S Ramsay |  | 23/11/2012 |
| | Laboratory Director | | |

FOREWORD

1. This report has been prepared by Sports Labs limited with all reasonable skill, care and diligence within the terms of the contract with the Client and within the limitations of the resources devoted to it.
2. This report is confidential to the Client and Sports Labs Limited accepts no responsibility whatsoever to third parties to whom this report, or any part thereof, is made known. Any such party relies upon the report at their own risk.
3. This report shall not be used for engineering or contractual purposes unless signed by the Author and the Checker and unless the report status is "Final".
4. * Not all tests carried out are within our scope of ISO 17025 Accreditation.
5. Comments and opinions are outwith the scope of our ISO 17025 accreditation



1.0 INTRODUCTION

1.1 We refer to the sample of synthetic carpet 'Turflex Premium' delivered to our Laboratory on 15th November 2012. The client requested testing to be carried out in accordance with the requirements of EN 13501-1– Flammability.

2.0 TEST DETAILS

2.1 The test Specimens were prepared in accordance with the specification requirements.

2.2 The sample was identified as 'Turflex Premium' and was tested with sand infill.

3.0 TESTING PROGRAMME

3.1 The test procedure used was in accordance with *EN ISO 11925-2:2002

3.2 System construction details can be seen below.

| Test Details | | |
|---|-------------|------------------------|
| Product Name | | Turflex Premium |
| Carpet Name (Marketing Identification Terminology) | | Turflex Premium |
| Substrate | | Concrete |
| Infill | Stabilising | Silica sand 0.2 -0.8mm |



4.0 Test Results

4.1 The results for the analysis of EN 13501-1– Flammability on the sample identified as 'Turflex Premium' can be viewed below:

| Turflex Premium | |
|---|---|
| Test Results | |
| Measurement | filled |
| Visual Composition | does not reach 150mm |
| Classification E_{FL} | Meets the specification requirements |

NOTE: “The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use”

End of Report